


Product description
Noise Reduction Data Sheet

The test was made by DELTA, Akustik & Vibration (DANAK Reg. No. 116).
The following results are a transcript of the test report, DANAK 1982 rev.1.
A complete description of the test can be found in the test report.

Test Specifications:

Laboratory: DS/EN ISO 140-1:1998
Measuring method: DS/EN ISO 140-3:1995
Evaluation: DS/EN ISO 717-1:1997

Panel type: AKU-1.1 (0,8)



Frequency f (Hz)	R 1/3-octave (dB)
100 125 160	17,0 17,6 18,8
200 250 315	19,8 23,0 23,6
400 500 630	27,0 26,2 33,0
800 1000 1250	37,3 37,8 41,7
1600 2000 2500	43,8 44,3 40,8
3150 4000 5000	34,9 32,9 36,3
R _w C C _{tr}	33 -1 -5

17,7

21,8

27,9

38,5

42,7

34,5